



Type Approval Certificate

This is to certify that the undernoted products have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER	BRUNO BALDASSARI & F.LLI S.p.A.		
PLACE OF PRODUCTION	BRUNO BALDASSARI & F.LLI S.p.A. Viale Europa, 118/120 55013 - Lammari (LU) Italy		
DESCRIPTION	Flexible single-core cable for internal wiring for maximum conductor temperature of 90°C, PVC compound insulation, TI3 quality.		
TYPE	H05V2-K		
APPLICATION	Fixed cabinet internal wiring.		
SPECIFIED STANDARDS	EN 50525-1:2012	EN 50525-2-31:2012	
RATINGS	Rated Voltages U ₀ /U [V]:	300/500 V	
	Maximum rated conductor temperature:	90°C	
RANGE	Single :	Number of Cores: 1	Cross Sectional Area [mm ²]: 0.50 ÷ 1.00

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No.19/00029 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No.	19/00029
Issue Date	04 June 2019
Expiry Date	03 June 2024
Sheet	1 of 1

M. Crucil
Trieste Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA

Southampton Boldrewood Innovation Campus, Burgess Road, Southampton SO16 7QF

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group