



No.701856/2017

- | | | | | |
|----|--|--|--------------------|------------------|
| 1. | Unique identification code of the product-type: | Power cable NYY
(multicore, circular copper conductor, class 1 or 2) | | |
| 2. | Intended use/es: | Supply of electricity | | |
| 3. | Manufacturer: | PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.
Ke Kablu 278
102 00 Prague 10 (HOSTIVÁŘ)
Czech republic | | |
| 4. | Authorised representative: | - | | |
| 5. | System/s of AVCP: | 3 | | |
| 6. | Harmonised standard: | EN 50575:2014+A1:2016 | | |
| | Notified body/ies: | No. 1014
Electrotechnical testing institute
Pod Lisem 129
171 02 Prague 8 – Troja
Czech republic | | |
| 7. | Declared performance/s: | Reaction to fire | E _{ca} | |
| | | Dangerous substances | NPD | |
| 8. | Appropriate Technical Documentation and/or Specific Technical Documentation: | Classification report No. | 701856-01/01 CLASS | from 2. 6. 2017 |
| | | Test report | 701856-01/01 | from 31. 5. 2017 |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 7.6.2017

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO