

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**with type designation(s)
BETAtherm 145- halogen free 0,6/1 kV

Issued to

LEONI Studer AG
Däniken SO, Switzerlandis found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Voltage class (kV) 0,6/1**
Temp. class (°C) 90Issued at **Hamburg** on **2017-01-30**This Certificate is valid until **2021-06-30**.DNV GL local station: **Augsburg**Approval Engineer: **Carsten Hunsalz**for **DNV GL**

Duy Nam Le
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type: BETAtherm 145 halogenfree 1 kV

Construction: Single wire
 Conductors: Tinned or plain stranded copper.
 Core insulation: HF 90

Number of cores x conductor cross-section	Overall diameter
mm ²	mm
1,0	2,4±0,3
1,5	3,0±0,5
2,5	3,7±0,5
4,0	4,2±0,6
6,0	4,8±0,8
10,0	6,3±0,8

Number of cores x conductor cross-section	Overall diameter
mm ²	mm
16,0	7,3±0,8
25,0	9,6±1,0
35,0	10,7±1,0
50,0	13,0±1,0
70,0	15,0±1,0
95,0	17,3±1,0

Number of cores x conductor cross-section	Overall diameter
mm ²	mm
120,0	19,2±1,0
150,0	21,4±1,0
185,0	23,6±1,5
240,0	26,7±1,5
300,0	30,6±1,5

Application/Limitation

Wires with flexible conductors (IEC 228 class 5) are to be terminated using approved compression terminals intended and designed for these conductors.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Single wire. General power and lighting. Flame retardant in bunch Cat. A. Halogen free. Low smoke.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3kV	
IEC 60332-1-2	2004-7	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22 IEC 60332-3-24	2009-02	Tests on electric cables under fire conditions - Part 3-22/24: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A/C	Bunch test Category A/C
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions - Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Job Id: **262.1-013803-3**
Certificate No: **TAE00001RU**

Standard	Release	General description	Limitation
IEC 60811-1-4	2001	Insulating and sheathing materials of electric and optical cables - Common test methods - Part 1-4: General application; Tests at low temperature	rated -40 °C
EN 50264-1	2008-06	Railway applications - Railway rolling stock power and control cables having special fire performance - Part 1: General requirements	Mineral oil resistance 72h/100°C Oil IRM 902 Fuel resistance 168h/70°C Liquid IRM 903 apply to insulation

Marking of product

STUDERCABLES.COM SWITZERLAND BETATHERM 145 HALOGEN FREE - size - 0,6/1 kV - Lot No.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE