

PRESTANDEDEKLARATION (DoP)
enligt bilaga III till förordningen (EU) nr 305/2011
Declaration of Performance
According to Annex III of Regulation (EU) no. 305/2011

Dokumentnummer
Document-no.

CPR-1011

1. Produkttypens unika identifikationskod
Unique identification code of the product type

420-3

2. Användning
Usage

Kablar och ledningar för allmän användning i byggnader med avseende på kraven på brandbeteende
Cables for general applications in construction works subject to reaction to fire requirements

3. Tillverkare
Manufacturer

BELCOM Cables Ltd
Green Street
Elsenham , CM22 6DS

4. Systemet för bedömning och fortlöpande kontroll av byggproduktens prestanda
System of assessment and verification of constancy of performance

System 3

5. Prestandadeklarationen avser en byggprodukt som omfattas av den harmoniserade standarden **EN 50575:2014+A1:2016**
This Declaration of Performance concerns a construction product which is covered by the harmonized standard EN 50575:2014+A1:2016

6. Tekniskt bedömningsorgan
product certification body

0832

7. Angiven prestanda
Declared Performance

Väsentliga egenskaper <i>Essential characteristics</i>	Prestanda <i>Performance</i>	Harmoniserad teknisk standard <i>Harmonized technical standard</i>
Reaktion vid brandpåverkan <i>Reaction to fire</i>	Eca	EN 50575:2014+A1:2016
Farliga ämnen <i>Hazardous substances</i>	NPD	

8. Prestandan för den produkt som anges i punkt 1 överensstämmer med den prestanda som anges i punkt 7.
The performance of the referred product in paragraphs 1 is in conformity with the declared performance in Section 7.

Denna prestandadeklaration utfärdas på eget ansvar av den tillverkare som anges under punkt 3.
This declaration of performance is issued under the general responsibilities listed in section 3. Manufacturer.

Undertecknat för tillverkaren av:
Signed for and in name of the manufacturer by:

Se nästa blad 

Declaration of Performance



DoP reference number : CPR-1011

- 1, Unique Identifier : 420-3
- 2, Intended use : Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- 3, Contact address : Belcom Cables Ltd
Green Street,
Elsenham,
CM22 6DS
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 0832 - BRE GLOBAL
- 7, Declared Performances :

Essential Characteristics	AVCP	Performance	Harmonized technical specification
Reaction to fire	System 3	Eca	EN 50575:2014 + A1:2016
Dangerous substances		None	

- 8, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

Test method & test report number.	Parameter	No. test runs	Results	
			Continuous parameter - mean (m)	Compliance with parameters Criterion for E
EN 60332-1-2 P107455-1068 Issue: 1	H	1	141 mm	H < 425mm / Compliant

Signed for and on behalf of the manufacturer by:

HSEQ Manager :

M. Dobson :

Director :

K. Ewing